



Ref. Certif. No.

**PL 2 0650**

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

**CB TEST CERTIFICATE**

Product

Empty enclosures

Name and address of the applicant

PCE POLSKA Sp. z o.o.  
ul. Podwalna 8A  
58-200 Dzierżoniów, Poland

Name and address of the manufacturer

PCE POLSKA Sp. z o.o.  
ul. Podwalna 8A  
58-200 Dzierżoniów, Poland

Name and address of the factory

PCE POLSKA Sp. z o.o.  
ul. Podwalna 8A  
58-200 Dzierżoniów, Poland

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

U<sub>i</sub>: 1 000 V a.c.; U<sub>i</sub>: 1 500 V d.c.; IP54; IK08

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

---

Model / Type Ref.

Series: Opole  
Type: 9092110; 9092210; 9092111; 9092211;  
9092112; 9092212; 9092113; 9092213.

Additional information (if necessary may also be reported on page 2)

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 62208:2011

As shown in the Test Report Ref. No. which forms part of this Certificate

LA-21.046/21.017/E

This CB Test Certificate is issued by the National Certification Body



SEP -BBJ  
ul. M. Pożaryskiego 28  
04-703 Warszawa  
POLAND

Phone: +48 22 812 69 38  
Fax: +48 22 815 65 80  
e-mail: bbj@bbj.pl



*A. Rybski*

Signature: Andrzej Rybski

Date: 2021-07-26

Type	Description.	Dimensions [mm]		
		Width	Height	Depth
9092110	dark, full with handle	300	405	128
9092210	light, full with handle			
9092111	dark, 5GS 3CEE with handle			
9092211	light, 5GS 3CEE with handle			
9092112	dark, 4GS 2CEE with handle			
9092212	light, 4GS 2CEE with handle			
9092113	dark, 3GS 2CEE with handle			
9092213	light, 3GS 2CEE with handle			
CEE – opening for power socket 16/32 A, 3/4/5-pole, GS – opening for 1-phase socket of FR/BEL and GER/AT system				

Thermal power dissipation capability acc. IEC TR 60890:2014: 47,6 W.  
For outdoor and indoor use.  
IP54 - with the enclosure cover closed.

**Additional information (if necessary)**

Date: 2021-07-26



*A. Rybski*  
Signature: Andrzej Rybski